
TruFLOW Jr. assemblies with balancing valves and valveless manifolds

uponor

Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

Technical data		
Material	Brass	
Manifold size	1 inch	
Loop Cv	1.9 Cv	
End type 1	ISO 228-G 1-1/4"	
End type 2	ISO 228-G 3/4"	
Temp/pressure ratings	73 °F (23 °C) at 160 psi (11 bar)	
	180 °F (82 °C) at 100 psi (6.9 bar)	
	200 °F (93 °C) at 80 psi (5.5 bar)	
Max. fluid flow rate	14 gpm	
Prop 65 label required?	Yes	
Product information and appl	ication use	





The TruFLOW[™] Jr. Assembly with Balancing Valves and Valveless is fully assembled and ready for installation. Use the TruFLOW Balancing Hex Key on the internal balancing valves of the supply manifold to balance the loops across the manifold. The manifold body ends have R32 unions, and the loop outlets have R20 male threads.

Part name		Part no.	A [inch]	B [inch]	C [inch]	D [inch]	E [inch]	F [inch]	G [inch]	H [inch]	Weight per UOM [lbs/UOM]
H-Insulation Kit, 5.5", 6.9"	', 7.9	A2660200	7.185	11.237	2.919	1.969	1.989	1.285	2.013	1.85	5.2
Part name	Part no.	Codes			Standards			Listings			
TruFLOW Jr. assemblies with balancing valves and valveless manifolds	A2660200	IMC II	IMC IRC NBC of Canada UMC			CSA B137.5 R32: ISO 228-G 1½" ASTM F877 R20: ISO 228-G ¾"			cNSFus-r	fh	

Installation	Related applications
TruFLOW Jr. Manifolds are fully assembled ready for installation. The TruFLOW Balancing Hex Key is used on the internal balancing valves of the supply manifold. Refer to the Uponor TruFLOW Jr. Manifold Instruction Sheet for further information.	Radiant Heating and Cooling Systems
	Permafrost Prevention Systems
	Turf Conditioning Systems

Notes

Manifold body threaded connections: R32 Manifold loop threaded connections: R20

Footnotes	Contact ir	Contact information			
	Uponor Inc.	Uponor Ltd.			
	5925 148th Street West	6510 Kennedy Road			
	Apple Valley, MN 55124	Mississauga, ON L5T 2X4			
	T 800.321.4739	T 888.594.7726			
	F 952.891.2008	F 800.638.9517			