
TruFLOW Jr. assemblies with balancing valves and valveless manifolds

uponor

Location:
Date submitted:
Submitted by:
Approved by:

Technical data	
Material	Brass
Manifold size	1 inch
Loop Cv	1.9 Cv
End type 1	ISO 228-G 1-1/4"
End type 2	ISO 228-G 3/4"
Temp/pressure ratings	73 °F (23 °C) at 160 psi (11 bar)
	180 °F (82 °C) at 100 psi (6.9 bar)
	200 °F (93 °C) at 80 psi (5.5 bar)
Max. fluid flow rate	14 gpm
Prop 65 label required?	Yes
Product information and applicati	ion use





The TruFLOW[™] Jr. Assembly with Balancing Valves and Valveless is fully assembled and ready for installation. Use the TruFLOW Balancing Hex Key on the internal balancing valves of the supply manifold to balance the loops across the manifold. The manifold body ends have R32 unions, and the loop outlets have R20 male threads.

Part name	Part no.	A [inch]	B [inch]	C [inch]	D [inch]	E [inch]	F [inch]	G [inch]	H [inch]	Weight per UOM [lbs/UOM]
H-Insulation Kit, 5.5", 6.9", 7.9	A2660200	7.185	11.237	2.919	1.969	1.989	1.285	2.013	1.85	5.2
TruFLOW Jr. Assembly, Balancing Valves and Valveless, 3- loop	A2660300	9.154	11.237	2.919	1.969	1.989	1.285	2.013	1.969	5.16
TruFLOW Jr. Assembly, Balancing Valves and Valveless, 5- loop	A2660500	13.091	11.237	2.919	1.969	1.989	1.285	2.013	5.906	9.97
TruFLOW Jr. Assembly, Balancing Valves and Valveless, 6- loop	A2660600	15.059	11.237	2.919	1.969	1.989	1.285	2.013	7.875	12.8
TruFLOW Jr. Assembly, Balancing Valves and Valveless, 7- loop	A2660700	17.028	11.237	2.919	1.969	1.989	1.285	2.013	9.843	14.1
TruFLOW Jr. Assembly, Balancing Valves and Valveless, 8- loop	A2660800	18.996	11.237	2.919	1.969	1.989	1.285	2.013	11.811	15.2

Part name	Part no.	Codes	Standards	Listings
TruFLOW Jr. assemblies with balancing valves and valveless manifolds	All	IMC IRC NBC of Canada UMC	CSA B137.5 R32: ISO 228-G 1¼" ASTM F877 R20: ISO 228-G ¾"	cNSFus-rfh

Installation	Related applications
TruFLOW Jr. Manifolds are fully assembled ready for installation. The TruFLOW Balancing Hex Key	Radiant Heating and Cooling Systems
is used on the internal balancing valves of the supply manifold. Refer to the Uponor TruFLOW Jr.	Permafrost Prevention Systems
Manifold Instruction Sheet for further information.	Turf Conditioning Systems

Notes

Manifold body threaded connections:

R32

Manifold loop threaded connections: R20

Footnotes	Contact Information		
	Uponor Inc.	Uponor Ltd.	
	5925 148th Street West	6510 Kennedy Road	
	Apple Valley, MN 55124	Mississauga, ON L5T 2X4	
	T 800.321.4739	T 888.594.7726	
	F 952.891.2008	F 800.638.9517	