
TruFLOW Jr. supply manifolds with balancing valves

υροποι

Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

Brass
1 inch
1.9 Cv
ISO 228-G 1-1/4"
ISO 228-G 3/4"
73 °F (23 °C) at 160 psi (11 bar)
180 °F (82 °C) at 100 psi (6.9 bar)
200 °F (93 °C) at 80 psi (5.5 bar)
14 gpm
Yes
ation use





Use the TruFLOW™ Jr. Manifold with Balancing Valves in conjunction with the TruFLOW Jr. Manifold with Isolation Valves or the TruFLOW Jr. Valveless Manifold to complete the manifold set. The TruFLOW Jr. Manifold with Balancing Valves allows manual flow balancing of the individual loops on the manifold.

Part name		Pa	Part no.		Weight per UOM [lbs/UOM]	
TruFLOW Jr. Manifold Balar	ncing Valves, 2-loop	A2	2663212		2.4	
Part name	Part no.	Codes		Standards	Listings	
TruFLOW Jr. supply manifolds with balancing valves	A2663212	IMC IRC NBC of Ca	anada UMC	CSA B137.5 R32: ISO 228-G 1¼" ASTM F877 R20: ISO 228-G ¾"	cNSFus-rfh	
Installation			Related application	ons		
For more information, refer to the Uponor TruFLOW Jr. Manifold Instruction Sheet or the Uponor Complete Design Assistance Manual. Accessories: TruFLOW Jr. Manifold Bracket: A2640021; End Cap with Vent: A2803250; Basic End Cap: A2080032.		Radiant Heating and Cooling Systems				
		Permafrost Prevention Systems				
		Turf Conditioning Systems				

Notes

Manifold body threaded connections: R32 Manifold loop threaded connections: R20

	Contact information		
Uponor Inc.	Uponor Ltd.		
5925 148th Street West	6510 Kennedy Road		
Apple Valley, MN 55124	Mississauga, ON L5T 2X4		
T 800.321.4739	T 888.594.7726		
F 952.891.2008	F 800.638.9517		
_	5925 148th Street West Apple Valley, MN 55124 T 800.321.4739		