EP heating manifold single sections with balancing valve and flow meter



| Project information | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Date submitted: |
| Contractor: | Submitted by: |
| Manufacturer's representative: | Approved by: |

Technical data

Subcomponent Material Manifold: PA66-GF30

Valve Insert, Handwheels: POM Metal Inserts: Brass C38500 Axel: Stainless Steel Spring: Stainless Steel O-ring: EPDM

Loop Cv 1.4 Cv


End type 1 ISO 228-G 3/4" Temp/pressure ratings 140 °F (60 °C) at 87 psi (6 bar)

158 °F (70 °C) at 72 psi (5 bar) 176 °F (80 °C) at 58 psi (4 bar) 194 °F (90 °C) at 44 psi (3 bar)

Operating temperature min. [°F] 44.6 °f Max. fluid flow rate 15.4 gpm Prop 65 label required? Yes

Product information and application use

The Engineered Polymer (EP) Heating Manifold Single Section with Balancing Valve and Flow Meter (A2670003) adds additional loops to an EP Heating Manifold assembly for use in hydronic radiant heating and cooling systems. Use only propylene glycol in radiant systems with EP Heating Manifolds; never use ethylene glycol.





| Part name | Part no. | Weight per UOM [lbs/UOM] |
|--|----------|--------------------------|
| EP Heating Manifold Single Section with Balancing Valve and Flow Meter | A2670003 | 0.46 |

| Installation | Related applications |
|--|---|
| Select the proper bracket spacing for the manifold and mount the bracket to the wall. Snap the manifold to the bracket. See the installation manual for complete instructions. Note: Use only propylene glycol in radiant heating and cooling systems with EP Heating Manifolds; never use | Radiant Heating and Cooling Systems Permafrost Protection Systems |
| ethylene glycol. Refer to the EP Heating Manifold Installation Guide for a complete chemicals list. | Turf Conditioning Systems |

Notes

Adaptable Actuators:

EP Heating Manifold, two-wire Actuator (A3030522); Thermal Actuator, four-wire (A3010522) with EP Heating Manifold Actuator Adaptor (A2671300) Connection Dimensions: R32

| Footnotes | Contact information | |
|-----------|------------------------|-------------------------|
| | Uponor Inc. | Uponor Ltd. |
| | 5925 148th Street West | 6510 Kennedy Road |
| - | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 |
| | T 800.321.4739 | T 888.594.7726 |
| | F 952.891.2008 | F 800.638.9517 |