

Tube clamps

| Project information | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Date submitted: |
| Contractor: | Submitted by: |
| Manufacturer's representative: | Approved by: |

Technical data

Material Plastic
Subcomponent Material Polypropylene (PP)
Product information and application use

Tube Clamps secure $\frac{1}{2}$ " and $\frac{3}{4}$ " Uponor crosslinked polyethylene (PEX-a) tubing products.



| Part name | Part no. | A [inch] | B [inch] | C [inch] | Weight per UOM [lbs/UOM] |
|---|----------|----------|----------|----------|-----------------------------|
| Tube Clamp Suspension (1/2 PEX), 100/pkg. | A7250500 | 2 | 1.407 | 0.75 | 0.01 |
| Tube Clamp Suspension (3/4 PEX), 50/pkg. | A7250750 | 2 | 1.672 | 0.75 | 0.01 |
| Tube Clamp Standard (1/2 PEX), 100/pkg. | A7350500 | 2 | 0.86 | 0.687 | 0.02 |
| Tube Clamp Standard (3/4 PEX), 50/pkg. | A7350750 | 2.375 | 1.125 | 0.687 | 0.02 |

| Installation | Related applications | |
|---|-------------------------------------|--|
| Fasten the tube clamp onto the tubing mounting surface. Refer to the Uponor Radiant Floor Installation Handbook or the Uponor Professional Plumbing Installation Guide for additional information | Radiant Heating and Cooling Systems | |
| | Permafrost Protection Systems | |
| | Turf Conditioning Systems | |
| | PEX-a Plumbing Systems | |
| | AquaSAFE™ Fire Safety Systems | |

| Footnotes | Contact information | | | |
|-----------|------------------------|-------------------------|--|--|
| | Uponor Inc. | Uponor Ltd. | | |
| | 5925 148th Street West | 6510 Kennedy Road | | |
| • | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 | | |
| | T 800.321.4739 | T 888.594.7726 | | |
| | F 952.891.2008 | F 800.638.9517 | | |