

PEX clips

Project Information

| | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Date submitted: |
| Contractor: | Submitted by: |
| Manufacturer's representative: | Approved by: |

Technical data

| | |
|-----------------------|---------|
| Material | Plastic |
| Subcomponent Material | Nylon |

Product Information and application use

Uponor PEX Clips are designed to suspend crosslinked polyethylene (PEX) tubing below the underside of a subfloor in a joist cavity installation.



| Part name | Part no. | A [inch] | B [inch] | C [inch] | Prop 65 label required? | Weight per UOM [lbs/UOM] |
|-------------------------|----------|----------|----------|----------|-------------------------|--------------------------|
| 3/8" PEX Clip, 100/pkg. | F7060375 | 0.685 | 1.14 | 1.613 | - | 0.015 |
| 1/2" PEX Clip, 100/pkg. | F7051258 | 0.685 | 1.14 | 1.676 | - | 0.016 |
| 3/4" PEX Clip, 100/pkg. | F7057500 | 0.685 | 1.386 | 1.912 | No | - |
| 1" PEX Clip, 50/pkg. | F7051001 | 0.685 | 1.77 | 2.202 | No | 0.03 |

Installation

Mount the PEX Clips to the underside of the subfloor in the joist cavity with the use of a drywall screw or nail. Secure the tubing to the clips at 36" intervals along the joist cavity. Refer to the Uponor Radiant Installation Handbook for additional information.

Related applications

Radiant Heating and Cooling Systems

Footnotes

-

Contact information

Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.638.9517