

Recessed pendent sprinklers

Project information

| | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Date submitted: |
| Contractor: | Submitted by: |
| Manufacturer's representative: | Approved by: |

Technical data

| | |
|-------------------------|-------------------------------------|
| Temp/pressure ratings | 73 °F (23 °C) at 160 psi (11 bar) |
| | 180 °F (82 °C) at 100 psi (6.9 bar) |
| | 200 °F (93 °C) at 80 psi (5.5 bar) |
| Prop 65 label required? | Yes |



| Part name | Part no. | Weight per UOM [lbs/UOM] |
|--|-----------|--------------------------|
| LF Recessed Pendent Sprinkler, 155F, 3.0 K-factor, White | LF73000WH | 0.15 |
| LF Recessed Pendent Sprinkler, 175F, 3.0 K-factor, White | LF73001WH | 0.15 |
| LF Recessed Pendent Sprinkler, 155F, 4.9 K-factor, White | LF74900WH | 0.15 |
| LF Recessed Pendent Sprinkler, 175F, 4.9 K-factor, White | LF74901WH | 0.15 |

Installation

-

Related applications

AquaSAFE™ Fire Safety Systems

Footnotes

-

Contact information

Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.638.9517