

# Brass manifold pressure test kits

## Project information

Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

## Technical data

Material	Brass
Subcomponent Material	Chrome Steel
Prop 65 label required?	Yes

## Product information and application use

The Uponor Brass Manifold Pressure Test Kit is for use with 1 1/4" Uponor TruFLOW™ Manifolds. Each kit contains an R32 x 3/4" manifold bushing, an R32 solid brass plug, and a 3/4" brass nipple and pressure gauge assembly (100 psi). A Schraeder valve is also included.



Part name	Part no.	Weight per UOM [lbs/UOM]
Manifold Pressure Test Kit	E6122000	1.82

## Installation

Thread one end of the 3/4" brass nipple into the pressure gauge assembly and the other end into the R32 x 3/4" brass plug. Thread the R32 x 3/4" brass plug into the inlet of the supply or return manifold. Thread the R32 solid brass plug into the inlet of the opposite manifold. Pressure the system with air to 60 psi. The system should maintain this pressure for at least 24 hours. For additional information, refer to the Uponor Radiant Installation Handbook.

## Related applications

Radiant Heating and Cooling Systems

## Footnotes

-

## Contact information

Uponor Inc.  
5925 148th Street West  
Apple Valley, MN 55124  
T 800.321.4739  
F 952.891.2008

Uponor Ltd.  
6510 Kennedy Road  
Mississauga, ON L5T 2X4  
T 888.594.7726  
F 800.638.9517