

EP heating manifold connection pieces

Project information

Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

Product information and application use

The Engineered Polymer (EP) Heating Manifold Connection Piece with R32 Union and Temperature Gauge (A2670032) transitions the manifold to the supply and return piping via an R32 union remote thread for use in hydronic radiant heating and cooling systems. Use only propylene glycol in radiant systems with EP Heating Manifolds; never use ethylene glycol.



Installation

Hand-tighten the connection piece onto the supply and return on the manifold. For additional information, refer to the EP Heating Manifold Installation Guide. Note: Use only propylene glycol in radiant heating and cooling systems with EP Heating Manifolds; never use ethylene glycol. Refer to the EP Heating Manifold Installation Guide for a complete chemicals list.

Related applications

Radiant Heating and Cooling Systems
 Permafrost Protection Systems
 Turf Conditioning Systems

Footnotes

Contact information

Uponor Inc.
 5925 148th Street West
 Apple Valley, MN 55124
 T 800.321.4739
 F 952.891.2008

Uponor Ltd.
 6510 Kennedy Road
 Mississauga, ON L5T 2X4
 T 888.594.7726
 F 800.638.9517