

# Uponor PP-RCT cold potable pipes, SDR 7.4

## Project information


|                                |                 |
|--------------------------------|-----------------|
| Job name:                      | Location:       |
| Engineer:                      | Date submitted: |
| Contractor:                    | Submitted by:   |
| Manufacturer's representative: | Approved by:    |

## Technical data

|                         |  |
|-------------------------|--|
| Material                | PP-RCT   |
| Temp/pressure ratings   | 73 °F (23 °C) at 335 psi (23 bar)<br>120 °F (49 °C) at 221 psi (15.2 bar)<br>180 °F (82 °C) at 100 psi (6.9 bar) |
| Prop 65 label required? | No   |

## Product information and application use

Use Uponor PP-RCT cold potable pipe to convey water for cold potable plumbing applications as well as other lower-pressure, lower-temperature applications.



| Part name   | Part no.   | Inner diameter pipe [Inch] | Outer diameter pipe [Inch] | Weight per UOM [lbs/UOM] |
|---|------------|----------------------------|----------------------------|--------------------------|
| 1/2" Uponor PP-RCT Cold Potable Pipe, SDR 7.4, 13-ft. straight length | PR72213500 | 0.567                      | 0.787                      | 1.3                      |
| 3/4" Uponor PP-RCT Cold Potable Pipe, SDR 7.4, 13-ft. straight length | PR72213750 | 0.709                      | 0.984                      | 2.08                     |

| Part name                                 | Part no. | Codes                                     | Standards   | Listings  |
|---|----------|---|---|---|
| Uponor PP-RCT cold potable pipes, SDR 7.4 | All      | UPC IRC IPC NPC of Canada UMC CMC CPC IMC | NSF/ANSI/CAN 61 ASTM E84 NSF/ANSI 51 ASTM F2389 CSA B137.11 | ICC-ES-PMG 1106 IAPMO-R&T 8358 QAI P321-5 IAPMO K-12775 |

## Installation

Use approved butt-fusion or socket-fusion connection methods. Refer to the Uponor PP-RCT manual for complete details.

## Related applications

| Footnotes   | Contact information  |   |   |
|---|--|---|---|
| -   | <table border="0"> <tr> <td>Uponor Inc.<br/>5925 148th Street West<br/>Apple Valley, MN 55124<br/>T 800.321.4739<br/>F 952.891.2008</td> <td>Uponor Ltd.<br/>6510 Kennedy Road<br/>Mississauga, ON L5T 2X4<br/>T 888.594.7726<br/>F 800.638.9517</td> </tr> </table> | Uponor Inc.<br>5925 148th Street West<br>Apple Valley, MN 55124<br>T 800.321.4739<br>F 952.891.2008 | Uponor Ltd.<br>6510 Kennedy Road<br>Mississauga, ON L5T 2X4<br>T 888.594.7726<br>F 800.638.9517 |
| Uponor Inc.<br>5925 148th Street West<br>Apple Valley, MN 55124<br>T 800.321.4739<br>F 952.891.2008 | Uponor Ltd.<br>6510 Kennedy Road<br>Mississauga, ON L5T 2X4<br>T 888.594.7726<br>F 800.638.9517  |   |   |