

Relais de pompe

Renseignements sur le projet

| | |
|-----------------------------|---------------------|
| Nom du poste : | Lieu : |
| Ingénieur : | Date de soumission: |
| Entrepreneur : | Présentée par: |
| Représentant du fabricant : | Approuvé par : |

Données techniques

Prop 65 label required? Yes

Informations sur le produit et utilisation de l'application

The Single-zone Pump relay controls the operation of a single circulator or pump from a 24-volt signal. The Three-zone Multi-pump Relay controls the operation of up to three pumps or circulators from dedicated 24-volt signals. The relay includes secondary low-voltage terminals for boiler operation and DHW priority options.



| Nom de la pièce | Numéro de pièce | Operating voltage AC [VAC] | Voltage secondary AC (50VA) [VAC] | Current draw max. [A] | Ambient humidity non-condensing max [%] | Weight per UOM [lbs/UOM] |
|-----------------------------|-----------------|----------------------------|-----------------------------------|-----------------------|-----------------------------------------|--------------------------|
| Single-zone Pump Relay | A3010100 | 120 | 24 | - | - | - |
| Three-zone Multi-pump Relay | A3080301 | 120 | - | 7.2 | 90 | - |

L'installation

Connect the thermostat to the "T T" terminals on the switching relay. When the thermostat calls for heat, the boiler is given a signal to start. The appropriate circulator is only energized when the boiler is above the set low limit. Refer to the Uponor Three-zone Multi-pump Relay Instruction Sheet for additional information.

Applications connexes

Radiant Heating and Cooling Systems

Remarques :

Indoor use only!

Maximum Zones:
3 with priority

Notes de bas de page

-

Coordonnées de la personne-ressource

Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.638.9517