

Régulateurs Smatrix Pulse avec modules de communication

Renseignements sur le projet

Nom du poste :	Lieu :
Ingénieur :	Date de soumission:
Entrepreneur :	Présentée par:
Représentant du fabricant :	Approuvé par :

Données techniques


Operating temperature min. [°F]	32 °f
Operating temperature max. [°F]	113 °f
Ambient temperature min. [F]	-4 °f
Ambient temperature max. [F]	158 °f
Ambient humidity non-condensing max [%]	85
Prop 65 label required?	Yes

Informations sur le produit et utilisation de l'application

Smatrix Pulse provides precise wireless control of radiant floor heating as well as forced-air heating and cooling systems in one solution that connects to a smart home assistant and can also be controlled remotely via the Smatrix Pulse App.

The Smatrix Pulse Controller (X-265) with Communication Module (R-208) connects up to six (6) thermostats and eight (8) actuators. The controller operates the actuators, which, in turn, affect the flow of the supply water to change the indoor temperature using information transmitted from the registered thermostats and system parameters.

Note: For the Smatrix Pulse Transformer (A3850050) and Communication Module (A3801208) technical data, refer to that individual product submittal or the Smatrix Pulse Installation and Operation Manual.



D: TRANSFORMER LENGTH AFTER INSTALLATION

Nom de la pièce	Numéro de pièce	A [inch]	B [inch]	C [inch]	D [inch]	E [inch]	Operating voltage AC [VAC]	Relay rating at 24VAC [A]	Weight per UOM [lbs/UOM]
Smatrix Pulse Controller (X-265) with Communication Module (R-208)	A380265C	13.268	4.331	2.165	3.307	4.331	115	2.5	3.9

Nom de la pièce	Numéro de pièce	Les codes	Normes	Annonces
Régulateurs Smatrix Pulse avec modules de communication	A380265C	-	FCC KDB996369 D04 IC RSS-210 ICC RSS-Gen FCC 47 CFR Part 15	IC 7664A-SM4NA1 FCC ID V9MSM4NA1

L'installation	Applications connexes
Refer to the Smatrix Pulse Installation and Operation Manual for installation information.	Radiant Hydronic Heating & Cooling Tools & Accessories

Notes de bas de page	Coordonnées de la personne-ressource		
-	<table border="0"> <tr> <td>Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008</td> <td>Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517</td> </tr> </table>	Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008	Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517
Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008	Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517		