

Xpress Trak

Renseignements sur le projet


Nom du poste :	Lieu :
Ingénieur :	Date de soumission:
Entrepreneur :	Présentée par:
Représentant du fabricant :	Approuvé par :

Données techniques

Material	Aluminum Laminate w/XPS Foam
Operating temperature min. [°F]	50 °f
Operating temperature max. [°F]	150 °f
R value	3.13
Prop 65 label required?	Yes

Informations sur le produit et utilisation de l'application

Designed for residential new construction and remodels, Xpress Trak™ is a radiant panel that features lightweight XPS foam laminated with aluminum for exceptional heat-transfer capability. Straight runs and return bends are integrated into one panel for quick, easy ordering. To install, simply adhere the panels to a wood subfloor or a concrete slab.



Nom de la pièce	Numéro de pièce	A [inch]	B [inch]	C [inch]	D [inch]	E [inch]	F [inch]	G [inch]	Weight per UOM [lbs/UOM]
Xpress Trak Radiant Panel, 6" o.c., 4 runs	A5070641	23.622	47.244	0.63	2.953	5.906	1.488	1.457	1.45

L'installation	Applications connexes
Use water-based sealant to adhere the panels to a wood subfloor or a concrete slab. Then, press the 5/16" Wirsbo hePEX™ pipe into the panel grooves using hands or feet. For further information, refer to the Xpress Trak Installation Guide.	Radiant heating

Notes de bas de page	Coordonnées de la personne-ressource		
-	<table border="0"> <tr> <td>Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008</td> <td>Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517</td> </tr> </table>	Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008	Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517
Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008	Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517		