

Antenne Smatrix Pulse (A-265), pièces de rechange

Renseignements sur le projet


Nom du poste :	Lieu :
Ingénieur :	Date de soumission:
Entrepreneur :	Présentée par:
Représentant du fabricant :	Approuvé par :

Données techniques

Operating temperature min. [°F]	32 °f
Operating temperature max. [°F]	113 °f
Ambient temperature min. [F]	-4 °f
Ambient temperature max. [F]	158 °f
Ambient humidity non-condensing max [%]	85
Prop 65 label required?	Yes

Informations sur le produit et utilisation de l'application

Use the Smatrix Pulse Antenna (A-265) replacement part to replace the antenna in the A380265A Smatrix Pulse Controller with Antenna. Smatrix Pulse provides precise wireless control of radiant floor heating as well as forced-air heating and cooling systems in one solution. The A380265A Smatrix Pulse Controller (X-265) with Antenna (A-265) connects up to six (6) thermostats and eight (8) actuators. The controller operates the actuators, which, in turn, affect the flow of the supply water to change the indoor temperature using information transmitted from the registered thermostats and system parameters.



ETHERNET CABLE LENGTH NOT TO SCALE

Nom de la pièce	Numéro de pièce	A [inch]	B [inch]	C [inch]	Operating voltage AC [VAC]	Weight per UOM [lbs/UOM]
Smatrix Pulse Antenna (A-265), replacement part	A3801265	4.331	1.181	0.394	115	0.28

Nom de la pièce	Numéro de pièce	Les codes	Normes	Annonces
Antenne Smatrix Pulse (A-265), pièces de rechange	A3801265	-	IC RSS-210 ICC RSS-Gen FCC 47 CFR Part 15	IC 7664A-SM4NA0 FCC ID V9MSM4NA0

L'installation

Refer to the Smatrix Pulse Installation and Operation Manual for installation information.

Applications connexes

- Radiant
- Hydronic Heating & Cooling
- Tools & Accessories

Notes de bas de page

Coordonnées de la personne-ressource

Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.638.9517