



CLEANLINESS CLASSIFICATION OF AIR-HANDLING COMPONENTS

Uponor Suomi Oy

The classification working group set up by the Building Information Foundation RTS sr has approved the following product manufactured by your company:

Non-insulated and insulated Uponor ventilation ducts and fittings made of polypropylene plastic (round duct Ø100,125,160,200 x length 3000mm, bend 45°, bend 90°, T-branch, connector, plug, reducer)

as belonging to cleanliness class M1 for air-handling components.

The classification is valid until January 13, 2024.

Uponor Suomi Oy has the right to equip its classified products with the classification mark and to use this classification mark when marketing these products.

The decision is in line with the requirements laid down in the Classification of Indoor Climate 2018 and the Cleanliness Classification of Air-handling Products, General Rules.

THE BUILDING INFORMATION FOUNDATION RTS sr

Markku Hedman
Director General

Arja Valtanen
Secretary of the Classification
Working Group