

Update 22.3.23

After further checks by our supplier Afriso-Euro-Index GmbH ("Afriso") of the products concerned, the existing product recall is adjusted as follows:

The UPONOR FLUVIA T PUMPGROUP PUSH-23-B-W Item No. 1078304 products, used in radiant heating application, generally installed inside the manifold distribution cabinet, **supplied between 1 October 2022 and 22 February 2023** (affected amount: in whole of Europe a total of 2500 pump groups) may have faulty wiring that can – in exceptional cases - cause a dangerous electric shock that could result in serious bodily harm.

Customers must not connect the product to electric power. The product has been produced by Uponor's supplier Afriso-Euro-Index GmbH ("Afriso"). All customers are asked to send the product back.

Important: No changes to be made to the electrical connection of any Uponor Fluvia T Pump Group Push-23-B-W. Affected products that have been put into service and are functioning, must also be sent for testing.

Possible rework is allowed only in exceptional cases after agreement with our Service After Sales Department.