# 2" PEX Minimum Cut Length Technical Bulletin

### **Affected Products**

- All 2" Uponor PEX pipe and ProPEX° fittings
- Milwaukee® 2" ProPEX Expander Head (part no. 49-16-2613)
- Milwaukee® M18 FUEL™ ProPEX Expander Tool (part nos. 2932-20 and 2932-22XC)

## Issue

Using a minimum pipe cut length of 6" increases the likelihood of damaging the fitting when making a connection with the 2" ProPEX Expander Head (part no. 49-16-2613) on the Milwaukee M18 FUEL ProPEX Expander Tool (part nos. 2932-20 and 2932-22XC).

### **Corrective Action**

Increase the cut length for 2" PEX to 6%" to avoid possible damage to the fitting. Note that Uponor is updating the minimum cut length in the current manuals and associated documentation.

**Note:** Using a minimum cut length of 6" is acceptable when using 2" ProPEX Expander Heads (part no. 49-16-2614) on the Milwaukee M18 FORCE LOGIC™ ProPEX Expander Tool (part nos. 2633-20HD and 2633-22HD).

# **Questions?**

For additional questions, please contact your local Uponor representative.







**Uponor Inc.** 5925 148th Street West Apple Valley, MN 55124

T 800.321.4739F 952.891.2008

**Uponor Ltd.** 6510 Kennedy Road Mississauga, ON L5T 2X4

**T** 888.994.7726 **F** 800.638.9517

**Uponor** 

**Moving > Water**